

There is one amendment in the Technical Specification for System & HT Consumer Meters. It is requested to replace the following text given under "GENERAL TECHNICAL REQUIREMENTS" page-2 of above document:

4	SECONDARY VOLTAGE	Suitable for operation from 110V Ph-Ph or 63.5V Ph-N
---	-------------------	--

with

4	SECONDARY VOLTAGE	i) For CT/PT operated HT Meters- Suitable for operation from 110V Ph-Ph or 63.5V Ph-N ii) For Distribution Transformer & other LTCT operated Meters- Suitable for operation from 415 Volts Ph-Ph /or 240 Volts Ph-N
---	--------------------------	--